

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 7)**

Water Level of the accumulated water (at 7:00 on May 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,866 mm (55 mm decrease since 7:00 on May 6)	O.P.+ 2,911 mm (21 mm increase since 7:00 on May 6)	—
	Water level of Turbine Building	O.P.+ 2,666 mm (20 mm increase since 7:00 on May 6)	O.P.+ 2,871 mm (46 mm decrease since 7:00 on May 6)	O.P.+ 2,960 mm (19 mm increase since 7:00 on May 6)	O.P.+ 2,891 mm (17 mm increase since 7:00 on May 6)
	Water level of Reactor Building	O.P.+ 4,195 mm (44 mm decrease since 7:00 on May 6)	O.P.+ 3,010 mm (44 mm decrease since 7:00 on May 6)	O.P.+ 3,070 mm (20 mm increase since 7:00 on May 6)	O.P.+ 2,953 mm (9 mm increase since 7:00 on May 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,241 mm (Increase from initial level:5,458 mm, 3 mm increase since 7:00 on May 6) O.P.+ 1,711 mm (Increase from initial level:2,437 mm, 65 mm decrease since 7:00 on May 6) O.P.+ 4,236 mm (Water level from floor:440 mm, 3 mm increase since 7:00 on May 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:10 on May 1)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:34 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:32 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:52 on May 1 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.