

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 8)**

Water Level of the accumulated water (at 7:00 on May 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,811 mm (55 mm decrease since 7:00 on May 7)	O.P.+ 2,927 mm (16 mm increase since 7:00 on May 7)	—
	Water level of Turbine Building	O.P.+ 2,682 mm (16 mm increase since 7:00 on May 7)	O.P.+ 2,823 mm (48 mm decrease since 7:00 on May 7)	O.P.+ 2,978 mm (18 mm increase since 7:00 on May 7)	O.P.+ 2,906 mm (15 mm increase since 7:00 on May 7)
	Water level of Reactor Building	O.P.+ 4,152 mm (43 mm decrease since 7:00 on May 7)	O.P.+ 2,970 mm (40 mm decrease since 7:00 on May 7)	O.P.+ 3,090 mm (20 mm increase since 7:00 on May 7)	O.P.+ 2,961 mm (8 mm increase since 7:00 on May 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,243 mm (Increase from initial level:5,460 mm, 2 mm increase since 7:00 on May 7) O.P.+ 1,656 mm (Increase from initial level:2,382 mm, 55 mm decrease since 7:00 on May 7) O.P.+ 4,239 mm (Water level from floor:443 mm, 3 mm increase since 7:00 on May 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:10 on May 1)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:34 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:32 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:52 on May 1 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.