

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 9)**

Water Level of the accumulated water (at 7:00 on May 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,761 mm (50 mm decrease since 7:00 on May 8)	O.P.+ 2,944 mm (17 mm increase since 7:00 on May 8)	—
	Water level of Turbine Building	O.P.+ 2,701 mm (19 mm increase since 7:00 on May 8)	O.P.+ 2,782 mm (41 mm decrease since 7:00 on May 8)	O.P.+ 2,996 mm (18 mm increase since 7:00 on May 8)	O.P.+ 2,922 mm (16 mm increase since 7:00 on May 8)
	Water level of Reactor Building	O.P.+ 4,113 mm (39 mm decrease since 7:00 on May 8)	O.P.+ 2,931 mm (39 mm decrease since 7:00 on May 8)	O.P.+ 3,109 mm (19 mm increase since 7:00 on May 8)	O.P.+ 2,972 mm (11 mm increase since 7:00 on May 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,247 mm (Increase from initial level:5,464 mm, 4 mm increase since 7:00 on May 8) O.P.+ 1,733 mm (Increase from initial level:2,459 mm, 77 mm increase since 7:00 on May 8) O.P.+ 4,242 mm (Water level from floor:446 mm, 3 mm increase since 7:00 on May 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:10 on May 1)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:34 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:32 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:19 on May 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 9:04 AM on May 8, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 12:43 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 1:19 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.