

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 12)**

Water Level of the accumulated water (at 7:00 on May 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,675 mm (21 mm decrease since 7:00 on May 11)	O.P.+ 2,890 mm (38 mm decrease since 7:00 on May 11)	—
	Water level of Turbine Building	O.P.+ 2,751 mm (16 mm increase since 7:00 on May 11)	O.P.+ 2,709 mm (18 mm decrease since 7:00 on May 11)	O.P.+ 2,893 mm (52 mm decrease since 7:00 on May 11)	O.P.+ 2,916 mm (18 mm decrease since 7:00 on May 11)
	Water level of Reactor Building	O.P.+ 4,005 mm (33 mm decrease since 7:00 on May 11)	O.P.+ 2,839 mm (16 mm decrease since 7:00 on May 11)	O.P.+ 3,003 mm (63 mm decrease since 7:00 on May 11)	O.P.+ 2,990 mm (1 mm decrease since 7:00 on May 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,255 mm (Increase from initial level:5,472 mm, 2 mm increase since 7:00 on May 11) O.P.+ 2,427 mm (Increase from initial level:3,153 mm, 399 mm increase since 7:00 on May 11) O.P.+ 4,251 mm (Water level from floor:455 mm, 2 mm increase since 7:00 on May 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on May 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:34 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:32 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:19 on May 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.