

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 13)**

Water Level of the accumulated water (at 7:00 on May 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,752 mm (77 mm increase since 7:00 on May 12)	O.P.+ 2,853 mm (37 mm decrease since 7:00 on May 12)	—
	Water level of Turbine Building	O.P.+ 2,769 mm (18 mm increase since 7:00 on May 12)	O.P.+ 2,775 mm (66 mm increase since 7:00 on May 12)	O.P.+ 2,848 mm (45 mm decrease since 7:00 on May 12)	O.P.+ 2,891 mm (25 mm decrease since 7:00 on May 12)
	Water level of Reactor Building	O.P.+ 3,986 mm (19 mm decrease since 7:00 on May 12)	O.P.+ 2,881 mm (42 mm increase since 7:00 on May 12)	O.P.+ 2,955 mm (48 mm decrease since 7:00 on May 12)	O.P.+ 2,983 mm (7 mm decrease since 7:00 on May 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,260 mm (Increase from initial level:5,477 mm, 5 mm increase since 7:00 on May 12) O.P.+ 2,409 mm (Increase from initial level:3,135 mm, 18 mm decrease since 7:00 on May 12) O.P.+ 4,255 mm (Water level from floor:459 mm, 4 mm increase since 7:00 on May 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:14 on May 10 to 9:36 on May 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:34 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:32 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:19 on May 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.