Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 14)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on May 14)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,832 mm (80 mm increase since 7:00 on May 13)	O.P.+ 2,817 mm (36 mm decrease since 7:00 on May 13)	_
	Water level of Turbine Building	O.P.+ 2,785 mm (16 mm increase since 7:00 on May 13)	O.P.+ 2,848 mm (73 mm increase since 7:00 on May 13)	O.P.+ 2,805 mm (43 mm decrease since 7:00 on May 13)	O.P.+ 2,864 mm (27 mm decrease since 7:00 on May 13)
	Water level of Reactor Building	O.P.+ 3,996 mm (10 mm increase since 7:00 on May 13)	O.P.+ 2,950 mm (69 mm increase since 7:00 on May 13)	O.P.+ 2,914 mm (41 mm decrease since 7:00 on May 13)	O.P.+ 2,974 mm (9 mm decrease since 7:00 on May 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building	O.P.+ 4,271 mm (Increase from initial level:5,488 mm, 11 mm increase since 7:00 on May 13)		
		High Temperature Incinerator Building	O.P.+ 2,343 mm (Increase from initial level:3,069 mm, 66 mm decrease since 7:00 on May 13)		
		On-site Bunker Building	O.P.+ 4,256 mm (Water level from floor:460 mm, 1 mm increase since 7:00 on May 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	_	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:34 on April 24)	_
		Unit 5 and 6			
			_		
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:32 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:19 on May 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					