

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 16)**

Water Level of the accumulated water (at 7:00 on May 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,980 mm (67 mm increase since 7:00 on May 15)	O.P.+ 2,747 mm (36 mm decrease since 7:00 on May 15)	—
	Water level of Turbine Building	O.P.+ 2,819 mm (19 mm increase since 7:00 on May 15)	O.P.+ 2,977 mm (58 mm increase since 7:00 on May 15)	O.P.+ 2,734 mm (38 mm decrease since 7:00 on May 15)	O.P.+ 2,810 mm (27 mm decrease since 7:00 on May 15)
	Water level of Reactor Building	O.P.+ 4,043 mm (28 mm increase since 7:00 on May 15)	O.P.+ 3,081 mm (56 mm increase since 7:00 on May 15)	O.P.+ 2,833 mm (39 mm decrease since 7:00 on May 15)	O.P.+ 2,945 mm (14 mm decrease since 7:00 on May 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,295 mm (Increase from initial level:5,512 mm, 9 mm increase since 7:00 on May 15) O.P.+ 2,382 mm (Increase from initial level:3,108 mm, 98 mm increase since 7:00 on May 15) O.P.+ 4,263 mm (Water level from floor:467 mm, 3 mm increase since 7:00 on May 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:34 on April 24)	—
		Unit 5 and 6			
		Basement of Turbine Building →Temporary Tank		Transfer Completed	(From 10:00 on May 15 to 15:00 on May 15)
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:32 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:03 on May 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:47 AM on May 15, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 12:57 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 2:03 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.