

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 19)**

Water Level of the accumulated water (at 7:00 on May 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,920 mm (67 mm decrease since 7:00 on May 18)	O.P.+ 2,745 mm (25 mm increase since 7:00 on May 18)	—
	Water level of Turbine Building	O.P.+ 2,570 mm (14 mm increase since 7:00 on May 18)	O.P.+ 2,920 mm (60 mm decrease since 7:00 on May 18)	O.P.+ 2,801 mm (43 mm increase since 7:00 on May 18)	O.P.+ 2,754 mm (3 mm decrease since 7:00 on May 18)
	Water level of Reactor Building	O.P.+ 4,107 mm (11 mm increase since 7:00 on May 18)	O.P.+ 3,053 mm (54 mm decrease since 7:00 on May 18)	O.P.+ 2,895 mm (48 mm increase since 7:00 on May 18)	O.P.+ 2,888 mm (15 mm decrease since 7:00 on May 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,312 mm (Increase from initial level:5,529 mm, 2 mm increase since 7:00 on May 18) O.P.+ 2,175 mm (Increase from initial level:2,901 mm, 69 mm decrease since 7:00 on May 18) O.P.+ 4,270 mm (Water level from floor:474 mm, 3 mm increase since 7:00 on May 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:57 on May 17)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:34 on April 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:32 on April 24   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:00 on May 19   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 7:00 AM on May 19, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for the replacement of a booster pump.				

※ For quick publication of the data of water level, values are provided as reference values.