

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 21)**

Water Level of the accumulated water (at 7:00 on May 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,804 mm (54 mm decrease since 7:00 on May 20)	O.P.+ 2,810 mm (29 mm increase since 7:00 on May 20)	—
	Water level of Turbine Building	O.P.+ 2,598 mm (13 mm increase since 7:00 on May 20)	O.P.+ 2,819 mm (47 mm decrease since 7:00 on May 20)	O.P.+ 2,872 mm (31 mm increase since 7:00 on May 20)	O.P.+ 2,791 mm (20 mm increase since 7:00 on May 20)
	Water level of Reactor Building	O.P.+ 4,099 mm (8 mm decrease since 7:00 on May 20)	O.P.+ 2,961 mm (42 mm decrease since 7:00 on May 20)	O.P.+ 2,975 mm (36 mm increase since 7:00 on May 20)	O.P.+ 2,881 mm (No change since 7:00 on May 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,196 mm (Increase from initial level:5,413 mm, 60 mm decrease since 7:00 on May 20) O.P.+ 2,996 mm (Increase from initial level:3,722 mm, 539 mm increase since 7:00 on May 20) O.P.+ 4,276 mm (Water level from floor:480 mm, 3 mm increase since 7:00 on May 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:57 on May 17)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:06 on May 19)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on May 20 to 15:00 on May 20)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:44 on May 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:00 on May 19 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.