

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 22)**

Water Level of the accumulated water (at 7:00 on May 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,977 mm (173 mm increase since 7:00 on May 21)	O.P.+ 2,856 mm (46 mm increase since 7:00 on May 21)	—
	Water level of Turbine Building	O.P.+ 2,631 mm (33 mm increase since 7:00 on May 21)	O.P.+ 2,793 mm (26 mm decrease since 7:00 on May 21)	O.P.+ 2,926 mm (54 mm increase since 7:00 on May 21)	O.P.+ 2,818 mm (27 mm increase since 7:00 on May 21)
	Water level of Reactor Building	O.P.+ 4,241 mm (142 mm increase since 7:00 on May 21)	O.P.+ 2,963 mm (2 mm increase since 7:00 on May 21)	O.P.+ 3,039 mm (64 mm increase since 7:00 on May 21)	O.P.+ 2,892 mm (11 mm increase since 7:00 on May 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,149 mm (Increase from initial level:5,366 mm, 47 mm decrease since 7:00 on May 21) O.P.+ 2,882 mm (Increase from initial level:3,608 mm, 114 mm decrease since 7:00 on May 21) O.P.+ 4,280 mm (Water level from floor:484 mm, 4 mm increase since 7:00 on May 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:57 on May 17)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:06 on May 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:44 on May 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:00 on May 19 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.