

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 26)**

Water Level of the accumulated water (at 7:00 on May 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,732 mm (77 mm increase since 7:00 on May 25)	O.P.+ 2,863 mm (35 mm decrease since 7:00 on May 25)	—
	Water level of Turbine Building	O.P.+ 2,729 mm (23 mm increase since 7:00 on May 25)	O.P.+ 2,760 mm (67 mm increase since 7:00 on May 25)	O.P.+ 2,880 mm (74 mm decrease since 7:00 on May 25)	O.P.+ 2,885 mm (5 mm decrease since 7:00 on May 25)
	Water level of Reactor Building	O.P.+ 4,220 mm (44 mm decrease since 7:00 on May 25)	O.P.+ 2,855 mm (21 mm increase since 7:00 on May 25)	O.P.+ 2,998 mm (71 mm decrease since 7:00 on May 25)	O.P.+ 2,939 mm (16 mm increase since 7:00 on May 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,942 mm (Increase from initial level:5,159 mm, 38 mm decrease since 7:00 on May 25) O.P.+ 1,977 mm (Increase from initial level:2,703 mm, 100 mm decrease since 7:00 on May 25) O.P.+ 4,285 mm (Water level from floor:489 mm, No change since 7:00 on May 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 9:57 on May 17 to 9:51 on May 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:06 on May 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:44 on May 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 6:51 on May 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 6:51 AM on May 26, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for replacement of a booster pump.				

※ For quick publication of the data of water level, values are provided as reference values.