## Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 27)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on May 27)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,812 mm (80 mm increase since 7:00 on May 26)	O.P.+ 2,825 mm (38 mm decrease since 7:00 on May 26)	_
	Water level of Turbine Building	O.P.+ 2,750 mm (21 mm increase since 7:00 on May 26)	O.P.+ 2,830 mm (70 mm increase since 7:00 on May 26)	O.P.+ 2,821 mm (59 mm decrease since 7:00 on May 26)	O.P.+ 2,863 mm (22 mm decrease since 7:00 on May 26)
	Water level of Reactor Building	O.P.+ 4,234 mm (14 mm increase since 7:00 on May 26)	O.P.+ 2,931 mm (76 mm increase since 7:00 on May 26)	O.P.+ 2,936 mm (62 mm decrease since 7:00 on May 26)	O.P.+ 2,936 mm (3 mm decrease since 7:00 on May 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building	O.P.+ 3,962 mm (Increase from initial level:5,179 mm, 20 mm increase since 7:00 on May 26)		
		High Temperature Incinerator Building	O.P.+ 1,989 mm (Increase from initial level:2,715 mm, 12 mm increase since 7:00 on May 26)		
		On-site Bunker Building	O.P.+ 4,286 mm (Water level from floor:490 mm, 1 mm increase since 7:00 on May 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	_	Basement of Unit 3 Turbine Building  →Centralized Radiation Waste  Treatment Facility (Process Main  Building)  Currently being transferred  (Since 10:06 on May 19)	_
		Unit 5 and 6			
			_		
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:44 on May 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 6:51 on May 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					