Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 28)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on May 28)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,897 mm (85 mm increase since 7:00 on May 27)	O.P.+ 2,786 mm (39 mm decrease since 7:00 on May 27)	_
	Water level of Turbine Building	O.P.+ 2,775 mm (25 mm increase since 7:00 on May 27)	O.P.+ 2,903 mm (73 mm increase since 7:00 on May 27)	O.P.+ 2,776 mm (45 mm decrease since 7:00 on May 27)	O.P.+ 2,835 mm (28 mm decrease since 7:00 on May 27)
	Water level of Reactor Building	O.P.+ 4,254 mm (20 mm increase since 7:00 on May 27)	O.P.+ 3,002 mm (71 mm increase since 7:00 on May 27)	O.P.+ 2,880 mm (56 mm decrease since 7:00 on May 27)	O.P.+ 2,928 mm (8 mm decrease since 7:00 on May 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building	O.P.+ 3,973 mm (Increase from initial level:5,190 mm, 11 mm increase since 7:00 on May 27)		
		High Temperature Incinerator Building	O.P.+ 1,986 mm (Increase from initial level:2,712 mm, 3 mm decrease since 7:00 on May 27)		
		On-site Bunker Building	O.P.+ 4,287 mm (Water level from floor:491 mm, 1 mm increase since 7:00 on May 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	_	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:06 on May 19)	_
		Unit 5 and 6			
			_		
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:44 on May 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 6:51 on May 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					