

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 30)**

Water Level of the accumulated water (at 7:00 on May 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,934 mm (44 mm decrease since 7:00 on May 29)	O.P.+ 2,742 mm (2 mm decrease since 7:00 on May 29)	—
	Water level of Turbine Building	O.P.+ 2,818 mm (21 mm increase since 7:00 on May 29)	O.P.+ 2,928 mm (42 mm decrease since 7:00 on May 29)	O.P.+ 2,780 mm (55 mm increase since 7:00 on May 29)	O.P.+ 2,781 mm (26 mm decrease since 7:00 on May 29)
	Water level of Reactor Building	O.P.+ 4,256 mm (No change since 7:00 on May 29)	O.P.+ 3,055 mm (9 mm decrease since 7:00 on May 29)	O.P.+ 2,871 mm (41 mm increase since 7:00 on May 29)	O.P.+ 2,906 mm (13 mm decrease since 7:00 on May 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,015 mm (Increase from initial level:5,232 mm, 12 mm decrease since 7:00 on May 29) O.P.+ 1,983 mm (Increase from initial level:2,709 mm, 3 mm decrease since 7:00 on May 29) O.P.+ 4,289 mm (Water level from floor:493 mm, No change since 7:00 on May 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:35 on May 29)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:06 on May 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:28 on May 28 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 6:51 on May 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.