

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 2)**

Water Level of the accumulated water (at 7:00 on June 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,763 mm (50 mm decrease since 7:00 on June 1)	O.P.+ 2,788 mm (15 mm increase since 7:00 on June 1)	—
	Water level of Turbine Building	O.P.+ 2,551 mm (18 mm increase since 7:00 on June 1)	O.P.+ 2,784 mm (43 mm decrease since 7:00 on June 1)	O.P.+ 2,846 mm (12 mm increase since 7:00 on June 1)	O.P.+ 2,795 mm (12 mm increase since 7:00 on June 1)
	Water level of Reactor Building	O.P.+ 4,214 mm (25 mm decrease since 7:00 on June 1)	O.P.+ 2,917 mm (39 mm decrease since 7:00 on June 1)	O.P.+ 2,951 mm (15 mm increase since 7:00 on June 1)	O.P.+ 2,883 mm (3 mm decrease since 7:00 on June 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,005 mm (Increase from initial level:5,222 mm, 8 mm decrease since 7:00 on June 1) O.P.+ 1,976 mm (Increase from initial level:2,702 mm, 6 mm decrease since 7:00 on June 1) O.P.+ 4,295 mm (Water level from floor:499 mm, 3 mm increase since 7:00 on June 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:35 on May 29)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:06 on May 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:28 on May 31 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 6:51 on May 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.