

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 3)**

Water Level of the accumulated water (at 7:00 on June 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,707 mm (56 mm decrease since 7:00 on June 2)	O.P.+ 2,798 mm (10 mm increase since 7:00 on June 2)	—
	Water level of Turbine Building	O.P.+ 2,566 mm (15 mm increase since 7:00 on June 2)	O.P.+ 2,738 mm (46 mm decrease since 7:00 on June 2)	O.P.+ 2,860 mm (14 mm increase since 7:00 on June 2)	O.P.+ 2,806 mm (11 mm increase since 7:00 on June 2)
	Water level of Reactor Building	O.P.+ 4,184 mm (30 mm decrease since 7:00 on June 2)	O.P.+ 2,876 mm (41 mm decrease since 7:00 on June 2)	O.P.+ 2,964 mm (13 mm increase since 7:00 on June 2)	O.P.+ 2,882 mm (1 mm decrease since 7:00 on June 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,006 mm (Increase from initial level:5,223 mm, 1 mm increase since 7:00 on June 2) O.P.+ 1,977 mm (Increase from initial level:2,703 mm, 1 mm increase since 7:00 on June 2) O.P.+ 4,298 mm (Water level from floor:502 mm, 3 mm increase since 7:00 on June 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:35 on May 29)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:06 on May 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:28 on May 31 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 6:51 on May 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.