

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 4)**

Water Level of the accumulated water (at 7:00 on June 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,657 mm (50 mm decrease since 7:00 on June 3)	O.P.+ 2,811 mm (13 mm increase since 7:00 on June 3)	—
	Water level of Turbine Building	O.P.+ 2,583 mm (17 mm increase since 7:00 on June 3)	O.P.+ 2,695 mm (43 mm decrease since 7:00 on June 3)	O.P.+ 2,873 mm (13 mm increase since 7:00 on June 3)	O.P.+ 2,817 mm (11 mm increase since 7:00 on June 3)
	Water level of Reactor Building	O.P.+ 4,153 mm (31 mm decrease since 7:00 on June 3)	O.P.+ 2,838 mm (38 mm decrease since 7:00 on June 3)	O.P.+ 2,978 mm (14 mm increase since 7:00 on June 3)	O.P.+ 2,884 mm (2 mm increase since 7:00 on June 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,010 mm (Increase from initial level:5,227 mm, 4 mm increase since 7:00 on June 3) O.P.+ 1,982 mm (Increase from initial level:2,708 mm, 5 mm increase since 7:00 on June 3) O.P.+ 4,300 mm (Water level from floor:504 mm, 2 mm increase since 7:00 on June 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:35 on May 29)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:06 on May 19)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on June 3 to 15:00 on June 3)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:28 on May 31 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 6:51 on May 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.