

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 5)**

Water Level of the accumulated water (at 7:00 on June 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,605 mm (52 mm decrease since 7:00 on June 4)	O.P.+ 2,823 mm (12 mm increase since 7:00 on June 4)	—
	Water level of Turbine Building	O.P.+ 2,600 mm (17 mm increase since 7:00 on June 4)	O.P.+ 2,654 mm (41 mm decrease since 7:00 on June 4)	O.P.+ 2,885 mm (12 mm increase since 7:00 on June 4)	O.P.+ 2,829 mm (12 mm increase since 7:00 on June 4)
	Water level of Reactor Building	O.P.+ 4,118 mm (35 mm decrease since 7:00 on June 4)	O.P.+ 2,798 mm (40 mm decrease since 7:00 on June 4)	O.P.+ 2,992 mm (14 mm increase since 7:00 on June 4)	O.P.+ 2,888 mm (4 mm increase since 7:00 on June 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,012 mm (Increase from initial level:5,229 mm, 2 mm increase since 7:00 on June 4) O.P.+ 1,998 mm (Increase from initial level:2,724 mm, 16 mm increase since 7:00 on June 4) O.P.+ 4,303 mm (Water level from floor:507 mm, 3 mm increase since 7:00 on June 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:35 on May 29)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:06 on May 19)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on June 4 to 15:00 on June 4)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:35 on June 4 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 6:51 on May 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	From 8:35 on June 5, cesium adsorption apparatus apparatus has been stopped for exchanging the vessel.				

※ For quick publication of the data of water level, values are provided as reference values.