

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 6)**

Water Level of the accumulated water (at 7:00 on June 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,701 mm (96 mm increase since 7:00 on June 5)	O.P.+ 2,841 mm (18 mm increase since 7:00 on June 5)	—
	Water level of Turbine Building	O.P.+ 2,614 mm (14 mm increase since 7:00 on June 5)	O.P.+ 2,736 mm (82 mm increase since 7:00 on June 5)	O.P.+ 2,899 mm (14 mm increase since 7:00 on June 5)	O.P.+ 2,841 mm (12 mm increase since 7:00 on June 5)
	Water level of Reactor Building	O.P.+ 4,089 mm (29 mm decrease since 7:00 on June 5)	O.P.+ 2,832 mm (34 mm increase since 7:00 on June 5)	O.P.+ 3,014 mm (22 mm increase since 7:00 on June 5)	O.P.+ 2,892 mm (4 mm increase since 7:00 on June 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,845 mm (Increase from initial level:5,062 mm, 167 mm decrease since 7:00 on June 5) O.P.+ 2,004 mm (Increase from initial level:2,730 mm, 6 mm increase since 7:00 on June 5) O.P.+ 4,306 mm (Water level from floor:510 mm, 3 mm increase since 7:00 on June 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 10:35 on May 29 to 9:07 on June 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 10:06 on May 19 to 9:29 on June 5)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank		Transfer Completed	(From 10:00 on June 5 to 15:00 on June 5)
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:35 on June 6   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 6:51 on May 26   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:35 AM on June 5, we temporarily stopped the Cesium Adsorption Apparatus for a vessel replacement. At 1:29 PM on the same day, the apparatus was restarted after the replacement, and the steady flow rate was achieved at 1:35 PM on the same day. After that, at 8:35 AM on June 6, we temporarily stopped the Cesium Adsorption Apparatus for a vessel replacement.				

※ For quick publication of the data of water level, values are provided as reference values.