

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 9)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on June 9)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,947 mm (80 mm increase since 7:00 on June 8)	O.P.+ 2,907 mm (20 mm increase since 7:00 on June 8)	—
	Water level of Turbine Building	O.P.+ 2,660 mm (17 mm increase since 7:00 on June 8)	O.P.+ 2,944 mm (66 mm increase since 7:00 on June 8)	O.P.+ 2,975 mm (18 mm increase since 7:00 on June 8)	O.P.+ 2,895 mm (20 mm increase since 7:00 on June 8)
	Water level of Reactor Building	O.P.+ 4,224 mm (73 mm increase since 7:00 on June 8)	O.P.+ 3,045 mm (50 mm increase since 7:00 on June 8)	O.P.+ 3,092 mm (17 mm increase since 7:00 on June 8)	O.P.+ 2,932 mm (17 mm increase since 7:00 on June 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,887 mm (Increase from initial level:4,104 mm, 356 mm decrease since 7:00 on June 8) O.P.+ 2,046 mm (Increase from initial level:2,772 mm, 2 mm decrease since 7:00 on June 8) O.P.+ 4,314 mm (Water level from floor:518 mm, 2 mm increase since 7:00 on June 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6 —			
Operation condition of water treatment facility	Cesium Adsorption Apparatus: Since 14:58 on June 6 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 6:51 on May 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance				
Notes					

※ For quick publication of the data of water level, values are provided as reference values.