

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 10)**

Water Level of the accumulated water (at 7:00 on June 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,970 mm (23 mm increase since 7:00 on June 9)	O.P.+ 2,932 mm (25 mm increase since 7:00 on June 9)	—
	Water level of Turbine Building	O.P.+ 2,682 mm (22 mm increase since 7:00 on June 9)	O.P.+ 2,961 mm (17 mm increase since 7:00 on June 9)	O.P.+ 2,993 mm (18 mm increase since 7:00 on June 9)	O.P.+ 2,916 mm (21 mm increase since 7:00 on June 9)
	Water level of Reactor Building	O.P.+ 4,308 mm (84 mm increase since 7:00 on June 9)	O.P.+ 3,087 mm (42 mm increase since 7:00 on June 9)	O.P.+ 3,118 mm (26 mm increase since 7:00 on June 9)	O.P.+ 2,949 mm (17 mm increase since 7:00 on June 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,571 mm (Increase from initial level:3,788 mm, 316 mm decrease since 7:00 on June 9) O.P.+ 1,905 mm (Increase from initial level:2,631 mm, 141 mm decrease since 7:00 on June 9) O.P.+ 4,316 mm (Water level from floor:520 mm, 2 mm increase since 7:00 on June 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:30 on June 9)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 16:50 on June 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on June 6 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:29 on June 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 6:51 AM on May 26, we temporarily stopped the Cesium Adsorption Apparatus for a booster pump replacement. At 12:38 PM on June 9, the apparatus was restarted after the replacement, and the steady flow rate was achieved at 1:29 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.