

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 11)**

Water Level of the accumulated water (at 7:00 on June 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,948 mm (22 mm decrease since 7:00 on June 10)	O.P.+ 2,899 mm (33 mm decrease since 7:00 on June 10)	—
	Water level of Turbine Building	O.P.+ 2,707 mm (25 mm increase since 7:00 on June 10)	O.P.+ 2,951 mm (10 mm decrease since 7:00 on June 10)	O.P.+ 2,925 mm (68 mm decrease since 7:00 on June 10)	O.P.+ 2,919 mm (3 mm increase since 7:00 on June 10)
	Water level of Reactor Building	O.P.+ 4,341 mm (33 mm increase since 7:00 on June 10)	O.P.+ 3,065 mm (22 mm decrease since 7:00 on June 10)	O.P.+ 3,050 mm (68 mm decrease since 7:00 on June 10)	O.P.+ 2,960 mm (11 mm increase since 7:00 on June 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,523 mm (Increase from initial level:3,740 mm, 48 mm decrease since 7:00 on June 10) O.P.+ 1,860 mm (Increase from initial level:2,586 mm, 45 mm decrease since 7:00 on June 10) O.P.+ 4,319 mm (Water level from floor:523 mm, 3 mm increase since 7:00 on June 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:30 on June 9)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 16:50 on June 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on June 6 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:29 on June 9 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.