

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 12)**

Water Level of the accumulated water (at 7:00 on June 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,927 mm (21 mm decrease since 7:00 on June 11)	O.P.+ 2,874 mm (25 mm decrease since 7:00 on June 11)	—
	Water level of Turbine Building	O.P.+ 2,732 mm (25 mm increase since 7:00 on June 11)	O.P.+ 2,933 mm (18 mm decrease since 7:00 on June 11)	O.P.+ 2,893 mm (32 mm decrease since 7:00 on June 11)	O.P.+ 2,904 mm (15 mm decrease since 7:00 on June 11)
	Water level of Reactor Building	O.P.+ 4,366 mm (25 mm increase since 7:00 on June 11)	O.P.+ 3,057 mm (8 mm decrease since 7:00 on June 11)	O.P.+ 3,015 mm (35 mm decrease since 7:00 on June 11)	O.P.+ 2,954 mm (6 mm decrease since 7:00 on June 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,516 mm (Increase from initial level:3,733 mm, 7 mm decrease since 7:00 on June 11) O.P.+ 1,872 mm (Increase from initial level:2,598 mm, 12 mm increase since 7:00 on June 11) O.P.+ 4,320 mm (Water level from floor:524 mm, 1 mm increase since 7:00 on June 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:30 on June 9)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 16:50 on June 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:58 on June 6 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:27 on June 12 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:27 AM on June 12, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.