

# **Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 16)**

Water Level of the accumulated water (at 7:00 on June 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,936 mm (9 mm decrease since 7:00 on June 15)	O.P.+ 2,766 mm (29 mm decrease since 7:00 on June 15)	—
	Water level of Turbine Building	O.P.+ 2,662 mm (39 mm increase since 7:00 on June 15)	O.P.+ 2,938 mm (8 mm decrease since 7:00 on June 15)	O.P.+ 2,757 mm (43 mm decrease since 7:00 on June 15)	O.P.+ 2,825 mm (29 mm decrease since 7:00 on June 15)
	Water level of Reactor Building	O.P.+ 4,554 mm (44 mm decrease since 7:00 on June 15)	O.P.+ 3,042 mm (12 mm decrease since 7:00 on June 15)	O.P.+ 2,858 mm (48 mm decrease since 7:00 on June 15)	O.P.+ 2,936 mm (12 mm decrease since 7:00 on June 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,794 mm (Increase from initial level:5,011 mm, 319 mm increase since 7:00 on June 15) O.P.+ 1,697 mm (Increase from initial level:2,423 mm, 83 mm decrease since 7:00 on June 15) O.P.+ 4,335 mm (Water level from floor:539 mm, 2 mm increase since 7:00 on June 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:30 on June 9)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 16:50 on June 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:15 on June 12   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.