

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 18)**

Water Level of the accumulated water (at 7:00 on June 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,896 mm (31 mm decrease since 7:00 on June 17)	O.P.+ 2,769 mm (10 mm increase since 7:00 on June 17)	—
	Water level of Turbine Building	O.P.+ 2,729 mm (32 mm increase since 7:00 on June 17)	O.P.+ 2,903 mm (27 mm decrease since 7:00 on June 17)	O.P.+ 2,851 mm (47 mm increase since 7:00 on June 17)	O.P.+ 2,799 mm (3 mm increase since 7:00 on June 17)
	Water level of Reactor Building	O.P.+ 4,306 mm (108 mm decrease since 7:00 on June 17)	O.P.+ 3,024 mm (17 mm decrease since 7:00 on June 17)	O.P.+ 2,952 mm (53 mm increase since 7:00 on June 17)	O.P.+ 2,895 mm (16 mm decrease since 7:00 on June 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,877 mm (Increase from initial level:5,094 mm, 3 mm increase since 7:00 on June 17) O.P.+ 2,015 mm (Increase from initial level:2,741 mm, 273 mm increase since 7:00 on June 17) O.P.+ 4,342 mm (Water level from floor:546 mm, 3 mm increase since 7:00 on June 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 16:00 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on June 17 to 15:00 on June 17)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:22 on June 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:26 AM on June 17, we temporarily stopped the Cesium Adsorption Apparatus for vessel replacement. At 5:50 PM on the same day, the apparatus was restarted after the vessel replacement, and the steady flow rate was achieved at 6:22 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.