

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 19)**

Water Level of the accumulated water (at 7:00 on June 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,857 mm (39 mm decrease since 7:00 on June 18)	O.P.+ 2,792 mm (23 mm increase since 7:00 on June 18)	—
	Water level of Turbine Building	O.P.+ 2,759 mm (30 mm increase since 7:00 on June 18)	O.P.+ 2,871 mm (32 mm decrease since 7:00 on June 18)	O.P.+ 2,873 mm (22 mm increase since 7:00 on June 18)	O.P.+ 2,817 mm (18 mm increase since 7:00 on June 18)
	Water level of Reactor Building	O.P.+ 4,219 mm (87 mm decrease since 7:00 on June 18)	O.P.+ 2,997 mm (27 mm decrease since 7:00 on June 18)	O.P.+ 2,979 mm (27 mm increase since 7:00 on June 18)	O.P.+ 2,892 mm (3 mm decrease since 7:00 on June 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,880 mm (Increase from initial level:5,097 mm, 3 mm increase since 7:00 on June 18) O.P.+ 1,933 mm (Increase from initial level:2,659 mm, 82 mm decrease since 7:00 on June 18) O.P.+ 4,344 mm (Water level from floor:548 mm, 2 mm increase since 7:00 on June 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 16:00 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on June 18 to 15:00 on June 18)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:23 on June 19 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:23 AM on June 19, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.