

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 23)**

Water Level of the accumulated water (at 7:00 on June 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,689 mm (39 mm decrease since 7:00 on June 22)	O.P.+ 2,866 mm (17 mm increase since 7:00 on June 22)	—
	Water level of Turbine Building	O.P.+ 2,545 mm (295 mm decrease since 7:00 on June 22)	O.P.+ 2,731 mm (32 mm decrease since 7:00 on June 22)	O.P.+ 2,952 mm (20 mm increase since 7:00 on June 22)	O.P.+ 2,887 mm (17 mm increase since 7:00 on June 22)
	Water level of Reactor Building	O.P.+ 3,966 mm (48 mm decrease since 7:00 on June 22)	O.P.+ 2,864 mm (33 mm decrease since 7:00 on June 22)	O.P.+ 3,065 mm (20 mm increase since 7:00 on June 22)	O.P.+ 2,930 mm (14 mm increase since 7:00 on June 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,890 mm (Increase from initial level:5,107 mm, 3 mm increase since 7:00 on June 22) O.P.+ 1,768 mm (Increase from initial level:2,494 mm, 83 mm decrease since 7:00 on June 22) O.P.+ 4,355 mm (Water level from floor:559 mm, 2 mm increase since 7:00 on June 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 9:34 on June 22 to 18:28 on June 22)	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 16:00 on June 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:55 on June 19 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.