

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 24)**

Water Level of the accumulated water (at 7:00 on June 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,771 mm (82 mm increase since 7:00 on June 23)	O.P.+ 2,844 mm (22 mm decrease since 7:00 on June 23)	—
	Water level of Turbine Building	O.P.+ 2,568 mm (23 mm increase since 7:00 on June 23)	O.P.+ 2,803 mm (72 mm increase since 7:00 on June 23)	O.P.+ 2,893 mm (59 mm decrease since 7:00 on June 23)	O.P.+ 2,883 mm (4 mm decrease since 7:00 on June 23)
	Water level of Reactor Building	O.P.+ 3,926 mm (40 mm decrease since 7:00 on June 23)	O.P.+ 2,892 mm (28 mm increase since 7:00 on June 23)	O.P.+ 3,010 mm (55 mm decrease since 7:00 on June 23)	O.P.+ 2,934 mm (4 mm increase since 7:00 on June 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,891 mm (Increase from initial level:5,108 mm, 1 mm increase since 7:00 on June 23) O.P.+ 1,691 mm (Increase from initial level:2,417 mm, 77 mm decrease since 7:00 on June 23) O.P.+ 4,357 mm (Water level from floor:561 mm, 2 mm increase since 7:00 on June 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 16:00 on June 16 to 10:13 on June 23)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:55 on June 19 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.