

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 26)**

Water Level of the accumulated water (at 7:00 on June 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,943 mm (82 mm increase since 7:00 on June 25)	O.P.+ 2,781 mm (33 mm decrease since 7:00 on June 25)	—
	Water level of Turbine Building	O.P.+ 2,611 mm (21 mm increase since 7:00 on June 25)	O.P.+ 2,954 mm (73 mm increase since 7:00 on June 25)	O.P.+ 2,807 mm (40 mm decrease since 7:00 on June 25)	O.P.+ 2,836 mm (25 mm decrease since 7:00 on June 25)
	Water level of Reactor Building	O.P.+ 3,903 mm (4 mm decrease since 7:00 on June 25)	O.P.+ 3,041 mm (73 mm increase since 7:00 on June 25)	O.P.+ 2,913 mm (44 mm decrease since 7:00 on June 25)	O.P.+ 2,916 mm (11 mm decrease since 7:00 on June 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,895 mm (Increase from initial level:5,112 mm, 2 mm increase since 7:00 on June 25) O.P.+ 1,547 mm (Increase from initial level:2,273 mm, 70 mm decrease since 7:00 on June 25) O.P.+ 4,362 mm (Water level from floor:566 mm, 2 mm increase since 7:00 on June 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:26 on June 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:26 AM on June 26, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.