

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 27)**

Water Level of the accumulated water (at 7:00 on June 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,015 mm (72 mm increase since 7:00 on June 26)	O.P.+ 2,750 mm (31 mm decrease since 7:00 on June 26)	—
	Water level of Turbine Building	O.P.+ 2,630 mm (19 mm increase since 7:00 on June 26)	O.P.+ 3,013 mm (59 mm increase since 7:00 on June 26)	O.P.+ 2,770 mm (37 mm decrease since 7:00 on June 26)	O.P.+ 2,808 mm (28 mm decrease since 7:00 on June 26)
	Water level of Reactor Building	O.P.+ 3,911 mm (8 mm increase since 7:00 on June 26)	O.P.+ 3,105 mm (64 mm increase since 7:00 on June 26)	O.P.+ 2,875 mm (38 mm decrease since 7:00 on June 26)	O.P.+ 2,904 mm (12 mm decrease since 7:00 on June 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,897 mm (Increase from initial level:5,114 mm, 2 mm increase since 7:00 on June 26) O.P.+ 1,627 mm (Increase from initial level:2,353 mm, 80 mm increase since 7:00 on June 26) O.P.+ 4,365 mm (Water level from floor:569 mm, 3 mm increase since 7:00 on June 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:46 on June 26 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:26 AM on June 26, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 12:08 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 12:46 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.