

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 1)**

Water Level of the accumulated water (at 7:00 on July 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,861 mm (54 mm decrease since 7:00 on June 30)	O.P.+ 2,707 mm (20 mm increase since 7:00 on June 30)	—
	Water level of Turbine Building	O.P.+ 2,703 mm (18 mm increase since 7:00 on June 30)	O.P.+ 2,880 mm (45 mm decrease since 7:00 on June 30)	O.P.+ 2,804 mm (28 mm increase since 7:00 on June 30)	O.P.+ 2,751 mm (13 mm increase since 7:00 on June 30)
	Water level of Reactor Building	O.P.+ 4,006 mm (9 mm increase since 7:00 on June 30)	O.P.+ 3,012 mm (54 mm decrease since 7:00 on June 30)	O.P.+ 2,907 mm (34 mm increase since 7:00 on June 30)	O.P.+ 2,836 mm (9 mm decrease since 7:00 on June 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,906 mm (Increase from initial level:5,123 mm, 2 mm increase since 7:00 on June 30) O.P.+ 2,213 mm (Increase from initial level:2,939 mm, 68 mm decrease since 7:00 on June 30) O.P.+ 4,373 mm (Water level from floor:577 mm, 1 mm increase since 7:00 on June 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:52 on June 29)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:46 on June 26   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.