

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 2)**

Water Level of the accumulated water (at 7:00 on July 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,805 mm (56 mm decrease since 7:00 on July 1)	O.P.+ 2,727 mm (20 mm increase since 7:00 on July 1)	—
	Water level of Turbine Building	O.P.+ 2,723 mm (20 mm increase since 7:00 on July 1)	O.P.+ 2,832 mm (48 mm decrease since 7:00 on July 1)	O.P.+ 2,825 mm (21 mm increase since 7:00 on July 1)	O.P.+ 2,768 mm (17 mm increase since 7:00 on July 1)
	Water level of Reactor Building	O.P.+ 3,996 mm (10 mm decrease since 7:00 on July 1)	O.P.+ 2,967 mm (45 mm decrease since 7:00 on July 1)	O.P.+ 2,930 mm (23 mm increase since 7:00 on July 1)	O.P.+ 2,833 mm (3 mm decrease since 7:00 on July 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,908 mm (Increase from initial level:5,125 mm, 2 mm increase since 7:00 on July 1) O.P.+ 2,154 mm (Increase from initial level:2,880 mm, 59 mm decrease since 7:00 on July 1) O.P.+ 4,375 mm (Water level from floor:579 mm, 2 mm increase since 7:00 on July 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:52 on June 29)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:46 on June 26 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.