

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 3)**

Water Level of the accumulated water (at 7:00 on July 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,757 mm (48 mm decrease since 7:00 on July 2)	O.P.+ 2,746 mm (19 mm increase since 7:00 on July 2)	—
	Water level of Turbine Building	O.P.+ 2,743 mm (20 mm increase since 7:00 on July 2)	O.P.+ 2,790 mm (42 mm decrease since 7:00 on July 2)	O.P.+ 2,845 mm (20 mm increase since 7:00 on July 2)	O.P.+ 2,784 mm (16 mm increase since 7:00 on July 2)
	Water level of Reactor Building	O.P.+ 3,974 mm (22 mm decrease since 7:00 on July 2)	O.P.+ 2,928 mm (39 mm decrease since 7:00 on July 2)	O.P.+ 2,950 mm (20 mm increase since 7:00 on July 2)	O.P.+ 2,840 mm (7 mm increase since 7:00 on July 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,912 mm (Increase from initial level:5,129 mm, 4 mm increase since 7:00 on July 2) O.P.+ 2,104 mm (Increase from initial level:2,830 mm, 50 mm decrease since 7:00 on July 2) O.P.+ 4,377 mm (Water level from floor:581 mm, 2 mm increase since 7:00 on July 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:52 on June 29)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:23 on July 3 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:23 AM on July 3, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.