

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 7)**

Water Level of the accumulated water (at 7:00 on July 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,682 mm (71 mm increase since 7:00 on July 6)	O.P.+ 2,772 mm (25 mm decrease since 7:00 on July 6)	—
	Water level of Turbine Building	O.P.+ 2,816 mm (19 mm increase since 7:00 on July 6)	O.P.+ 2,730 mm (65 mm increase since 7:00 on July 6)	O.P.+ 2,835 mm (61 mm decrease since 7:00 on July 6)	O.P.+ 2,828 mm (4 mm decrease since 7:00 on July 6)
	Water level of Reactor Building	O.P.+ 3,886 mm (24 mm decrease since 7:00 on July 6)	O.P.+ 2,822 mm (17 mm increase since 7:00 on July 6)	O.P.+ 2,949 mm (58 mm decrease since 7:00 on July 6)	O.P.+ 2,878 mm (5 mm increase since 7:00 on July 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,919 mm (Increase from initial level:5,136 mm, 1 mm increase since 7:00 on July 6) O.P.+ 2,120 mm (Increase from initial level:2,846 mm, 33 mm decrease since 7:00 on July 6) O.P.+ 4,382 mm (Water level from floor:586 mm, 1 mm increase since 7:00 on July 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 9:52 on June 29 to 9:58 on July 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:48 on July 3 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.