

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 8)**

Water Level of the accumulated water (at 7:00 on July 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,763 mm (81 mm increase since 7:00 on July 7)	O.P.+ 2,741 mm (31 mm decrease since 7:00 on July 7)	—
	Water level of Turbine Building	O.P.+ 2,833 mm (17 mm increase since 7:00 on July 7)	O.P.+ 2,801 mm (71 mm increase since 7:00 on July 7)	O.P.+ 2,787 mm (48 mm decrease since 7:00 on July 7)	O.P.+ 2,807 mm (21 mm decrease since 7:00 on July 7)
	Water level of Reactor Building	O.P.+ 3,886 mm (No change since 7:00 on July 7)	O.P.+ 2,888 mm (66 mm increase since 7:00 on July 7)	O.P.+ 2,897 mm (52 mm decrease since 7:00 on July 7)	O.P.+ 2,868 mm (10 mm decrease since 7:00 on July 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,922 mm (Increase from initial level:5,139 mm, 3 mm increase since 7:00 on July 7) O.P.+ 2,100 mm (Increase from initial level:2,826 mm, 20 mm decrease since 7:00 on July 7) O.P.+ 4,384 mm (Water level from floor:588 mm, 2 mm increase since 7:00 on July 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 9:52 on June 29 to 9:58 on July 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:48 on July 3   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.