

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 10)**

Water Level of the accumulated water (at 7:00 on July 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,909 mm (77 mm increase since 7:00 on July 9)	O.P.+ 2,697 mm (17 mm decrease since 7:00 on July 9)	—
	Water level of Turbine Building	O.P.+ 2,870 mm (19 mm increase since 7:00 on July 9)	O.P.+ 2,926 mm (66 mm increase since 7:00 on July 9)	O.P.+ 2,752 mm (11 mm decrease since 7:00 on July 9)	O.P.+ 2,764 mm (20 mm decrease since 7:00 on July 9)
	Water level of Reactor Building	O.P.+ 3,988 mm (92 mm increase since 7:00 on July 9)	O.P.+ 3,035 mm (85 mm increase since 7:00 on July 9)	O.P.+ 2,861 mm (9 mm decrease since 7:00 on July 9)	O.P.+ 2,849 mm (11 mm decrease since 7:00 on July 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,926 mm (Increase from initial level:5,143 mm, 1 mm increase since 7:00 on July 9) O.P.+ 2,081 mm (Increase from initial level:2,807 mm, 5 mm decrease since 7:00 on July 9) O.P.+ 4,389 mm (Water level from floor:593 mm, 3 mm increase since 7:00 on July 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 9:52 on June 29 to 9:58 on July 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:22 on July 10 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:22 AM on July 10, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.