

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 14)**

Water Level of the accumulated water (at 7:00 on July 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,737 mm (45 mm decrease since 7:00 on July 13)	O.P.+ 2,758 mm (18 mm increase since 7:00 on July 13)	—
	Water level of Turbine Building	O.P.+ 2,676 mm (24 mm increase since 7:00 on July 13)	O.P.+ 2,777 mm (39 mm decrease since 7:00 on July 13)	O.P.+ 2,868 mm (18 mm increase since 7:00 on July 13)	O.P.+ 2,806 mm (16 mm increase since 7:00 on July 13)
	Water level of Reactor Building	O.P.+ 4,030 mm (30 mm decrease since 7:00 on July 13)	O.P.+ 2,898 mm (32 mm decrease since 7:00 on July 13)	O.P.+ 2,975 mm (19 mm increase since 7:00 on July 13)	O.P.+ 2,852 mm (11 mm increase since 7:00 on July 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,932 mm (Increase from initial level:5,149 mm, 2 mm increase since 7:00 on July 13) O.P.+ 2,252 mm (Increase from initial level:2,978 mm, 8 mm increase since 7:00 on July 13) O.P.+ 4,398 mm (Water level from floor:602 mm, 2 mm increase since 7:00 on July 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:28 on July 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:50 on July 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.