

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 15)**

Water Level of the accumulated water (at 7:00 on July 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,689 mm (48 mm decrease since 7:00 on July 14)	O.P.+ 2,774 mm (16 mm increase since 7:00 on July 14)	—
	Water level of Turbine Building	O.P.+ 2,697 mm (21 mm increase since 7:00 on July 14)	O.P.+ 2,735 mm (42 mm decrease since 7:00 on July 14)	O.P.+ 2,884 mm (16 mm increase since 7:00 on July 14)	O.P.+ 2,821 mm (15 mm increase since 7:00 on July 14)
	Water level of Reactor Building	O.P.+ 3,992 mm (38 mm decrease since 7:00 on July 14)	O.P.+ 2,859 mm (39 mm decrease since 7:00 on July 14)	O.P.+ 2,993 mm (18 mm increase since 7:00 on July 14)	O.P.+ 2,867 mm (15 mm increase since 7:00 on July 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,934 mm (Increase from initial level:5,151 mm, 2 mm increase since 7:00 on July 14) O.P.+ 2,269 mm (Increase from initial level:2,995 mm, 17 mm increase since 7:00 on July 14) O.P.+ 4,400 mm (Water level from floor:604 mm, 2 mm increase since 7:00 on July 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:28 on July 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:50 on July 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.