

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 16)**

Water Level of the accumulated water (at 7:00 on July 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,638 mm (51 mm decrease since 7:00 on July 15)	O.P.+ 2,791 mm (17 mm increase since 7:00 on July 15)	—
	Water level of Turbine Building	O.P.+ 2,718 mm (21 mm increase since 7:00 on July 15)	O.P.+ 2,690 mm (45 mm decrease since 7:00 on July 15)	O.P.+ 2,900 mm (16 mm increase since 7:00 on July 15)	O.P.+ 2,836 mm (15 mm increase since 7:00 on July 15)
	Water level of Reactor Building	O.P.+ 3,954 mm (38 mm decrease since 7:00 on July 15)	O.P.+ 2,817 mm (42 mm decrease since 7:00 on July 15)	O.P.+ 3,012 mm (19 mm increase since 7:00 on July 15)	O.P.+ 2,879 mm (12 mm increase since 7:00 on July 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,938 mm (Increase from initial level:5,155 mm, 4 mm increase since 7:00 on July 15) O.P.+ 2,292 mm (Increase from initial level:3,018 mm, 23 mm increase since 7:00 on July 15) O.P.+ 4,402 mm (Water level from floor:606 mm, 2 mm increase since 7:00 on July 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:28 on July 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:50 on July 10   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.