

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 17)**

Water Level of the accumulated water (at 7:00 on July 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,592 mm (46 mm decrease since 7:00 on July 16)	O.P.+ 2,816 mm (25 mm increase since 7:00 on July 16)	—
	Water level of Turbine Building	O.P.+ 2,737 mm (19 mm increase since 7:00 on July 16)	O.P.+ 2,652 mm (38 mm decrease since 7:00 on July 16)	O.P.+ 2,925 mm (25 mm increase since 7:00 on July 16)	O.P.+ 2,854 mm (18 mm increase since 7:00 on July 16)
	Water level of Reactor Building	O.P.+ 3,924 mm (30 mm decrease since 7:00 on July 16)	O.P.+ 2,779 mm (38 mm decrease since 7:00 on July 16)	O.P.+ 3,040 mm (28 mm increase since 7:00 on July 16)	O.P.+ 2,894 mm (15 mm increase since 7:00 on July 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,991 mm (Increase from initial level:5,208 mm, 53 mm increase since 7:00 on July 16) O.P.+ 2,315 mm (Increase from initial level:3,041 mm, 23 mm increase since 7:00 on July 16) O.P.+ 4,404 mm (Water level from floor:608 mm, 2 mm increase since 7:00 on July 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:28 on July 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 11:00 on July 16 to 15:00 on July 16)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:25 on July 17 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 7:25 AM on July 17, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a vessel exchange.				

※ For quick publication of the data of water level, values are provided as reference values.