

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 23)**

Water Level of the accumulated water (at 7:00 on July 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,930 mm (56 mm decrease since 7:00 on July 22)	O.P.+ 2,678 mm (5 mm decrease since 7:00 on July 22)	—
	Water level of Turbine Building	O.P.+ 2,892 mm (29 mm increase since 7:00 on July 22)	O.P.+ 2,941 mm (48 mm decrease since 7:00 on July 22)	O.P.+ 2,783 mm (56 mm increase since 7:00 on July 22)	O.P.+ 2,751 mm (18 mm decrease since 7:00 on July 22)
	Water level of Reactor Building	O.P.+ 4,096 mm (27 mm increase since 7:00 on July 22)	O.P.+ 3,069 mm (13 mm decrease since 7:00 on July 22)	O.P.+ 2,884 mm (54 mm increase since 7:00 on July 22)	O.P.+ 2,841 mm (18 mm decrease since 7:00 on July 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,017 mm (Increase from initial level:5,234 mm, 4 mm increase since 7:00 on July 22) O.P.+ 1,975 mm (Increase from initial level:2,701 mm, 87 mm decrease since 7:00 on July 22) O.P.+ 4,420 mm (Water level from floor:624 mm, 4 mm increase since 7:00 on July 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:50 on July 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:20 on July 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.