

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 24)**

Water Level of the accumulated water (at 7:00 on July 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,868 mm (62 mm decrease since 7:00 on July 23)	O.P.+ 2,694 mm (16 mm increase since 7:00 on July 23)	—
	Water level of Turbine Building	O.P.+ 2,921 mm (29 mm increase since 7:00 on July 23)	O.P.+ 2,889 mm (52 mm decrease since 7:00 on July 23)	O.P.+ 2,815 mm (32 mm increase since 7:00 on July 23)	O.P.+ 2,762 mm (11 mm increase since 7:00 on July 23)
	Water level of Reactor Building	O.P.+ 4,101 mm (5 mm increase since 7:00 on July 23)	O.P.+ 3,022 mm (47 mm decrease since 7:00 on July 23)	O.P.+ 2,919 mm (35 mm increase since 7:00 on July 23)	O.P.+ 2,835 mm (6 mm decrease since 7:00 on July 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,020 mm (Increase from initial level:5,237 mm, 3 mm increase since 7:00 on July 23) O.P.+ 1,894 mm (Increase from initial level:2,620 mm, 81 mm decrease since 7:00 on July 23) O.P.+ 4,422 mm (Water level from floor:626 mm, 2 mm increase since 7:00 on July 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:50 on July 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:25 on July 24 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* From 8:25 on July 24, we temporary stopped the Second Cesium Adsorption Apparatus (SARRY) for cleaning the filter.				

※ For quick publication of the data of water level, values are provided as reference values.