

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 28)**

Water Level of the accumulated water (at 7:00 on July 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,648 mm (49 mm decrease since 7:00 on July 27)	O.P.+ 2,778 mm (13 mm increase since 7:00 on July 27)	—
	Water level of Turbine Building	O.P.+ 3,013 mm (20 mm increase since 7:00 on July 27)	O.P.+ 2,698 mm (45 mm decrease since 7:00 on July 27)	O.P.+ 2,898 mm (15 mm increase since 7:00 on July 27)	O.P.+ 2,836 mm (15 mm increase since 7:00 on July 27)
	Water level of Reactor Building	O.P.+ 4,010 mm (30 mm decrease since 7:00 on July 27)	O.P.+ 2,837 mm (45 mm decrease since 7:00 on July 27)	O.P.+ 3,011 mm (16 mm increase since 7:00 on July 27)	O.P.+ 2,869 mm (9 mm increase since 7:00 on July 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,030 mm (Increase from initial level:5,247 mm, 2 mm increase since 7:00 on July 27) O.P.+ 1,729 mm (Increase from initial level:2,455 mm, 76 mm decrease since 7:00 on July 27) O.P.+ 4,453 mm (Water level from floor:657 mm, 10 mm increase since 7:00 on July 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:50 on July 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:35 on July 24   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.