

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 29)**

Water Level of the accumulated water (at 7:00 on July 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,603 mm (45 mm decrease since 7:00 on July 28)	O.P.+ 2,795 mm (17 mm increase since 7:00 on July 28)	—
	Water level of Turbine Building	O.P.+ 2,551 mm (462 mm decrease since 7:00 on July 28)	O.P.+ 2,660 mm (38 mm decrease since 7:00 on July 28)	O.P.+ 2,915 mm (17 mm increase since 7:00 on July 28)	O.P.+ 2,850 mm (14 mm increase since 7:00 on July 28)
	Water level of Reactor Building	O.P.+ 3,977 mm (33 mm decrease since 7:00 on July 28)	O.P.+ 2,791 mm (46 mm decrease since 7:00 on July 28)	O.P.+ 3,028 mm (17 mm increase since 7:00 on July 28)	O.P.+ 2,881 mm (12 mm increase since 7:00 on July 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,034 mm (Increase from initial level:5,251 mm, 4 mm increase since 7:00 on July 28) O.P.+ 1,664 mm (Increase from initial level:2,390 mm, 65 mm decrease since 7:00 on July 28) O.P.+ 4,464 mm (Water level from floor:668 mm, 11 mm increase since 7:00 on July 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Currently being transferred (Since 17:26 on July 28)	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:50 on July 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:35 on July 24   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.