

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 31)**

Water Level of the accumulated water (at 7:00 on July 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,518 mm (40 mm decrease since 7:00 on July 30)	O.P.+ 2,785 mm (30 mm decrease since 7:00 on July 30)	—
	Water level of Turbine Building	O.P.+ 2,483 mm (18 mm increase since 7:00 on July 30)	O.P.+ 2,590 mm (34 mm decrease since 7:00 on July 30)	O.P.+ 2,961 mm (22 mm increase since 7:00 on July 30)	O.P.+ 2,887 mm (19 mm increase since 7:00 on July 30)
	Water level of Reactor Building	O.P.+ 3,910 mm (33 mm decrease since 7:00 on July 30)	O.P.+ 2,723 mm (31 mm decrease since 7:00 on July 30)	O.P.+ 2,979 mm (76 mm decrease since 7:00 on July 30)	O.P.+ 2,909 mm (14 mm increase since 7:00 on July 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,120 mm (Increase from initial level:5,337 mm, 86 mm increase since 7:00 on July 30) O.P.+ 1,570 mm (Increase from initial level:2,296 mm, 38 mm decrease since 7:00 on July 30) O.P.+ 4,215 mm (Water level from floor:419 mm, 261 mm decrease since 7:00 on July 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:50 on July 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:53 on July 31   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*1 As for the water level of the vertical shaft at Unit 3, adjustment value has been changed from -450mm to -500mm since 7:00 AM on July 31, 2014. *2 As for the water level of Unit 3 Reactor Building, adjustment value has been changed from -400mm to -500mm since 7:00 AM on July 31, 2014. *3 From 10:11 AM to 7:09 PM on July 30, transfer of accumulated water from the On-site Bunker Building to the Process Main Building was conducted. *4 At 7:53 AM on July 31, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.