

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 1)**

Water Level of the accumulated water (at 7:00 on August 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,599 mm (81 mm increase since 7:00 on July 31)	O.P.+ 2,756 mm (29 mm decrease since 7:00 on July 31)	—
	Water level of Turbine Building	O.P.+ 2,500 mm (17 mm increase since 7:00 on July 31)	O.P.+ 2,662 mm (72 mm increase since 7:00 on July 31)	O.P.+ 2,894 mm (67 mm decrease since 7:00 on July 31)	O.P.+ 2,885 mm (2 mm decrease since 7:00 on July 31)
	Water level of Reactor Building	O.P.+ 3,884 mm (26 mm decrease since 7:00 on July 31)	O.P.+ 2,750 mm (27 mm increase since 7:00 on July 31)	O.P.+ 2,914 mm (65 mm decrease since 7:00 on July 31)	O.P.+ 2,920 mm (11 mm increase since 7:00 on July 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,123 mm (Increase from initial level:5,340 mm, 3 mm increase since 7:00 on July 31) O.P.+ 1,749 mm (Increase from initial level:2,475 mm, 179 mm increase since 7:00 on July 31) O.P.+ 4,225 mm (Water level from floor:429 mm, 10 mm increase since 7:00 on July 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 9:50 on July 22 to 10:05 on July 31)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:16 on July 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 7:53 AM on July 31, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 3:18 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 4:16 PM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.