

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 5)**

Water Level of the accumulated water (at 7:00 on August 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,913 mm (72 mm increase since 7:00 on August 4)	O.P.+ 2,625 mm (35 mm decrease since 7:00 on August 4)	—
	Water level of Turbine Building	O.P.+ 2,554 mm (12 mm increase since 7:00 on August 4)	O.P.+ 2,928 mm (58 mm increase since 7:00 on August 4)	O.P.+ 2,727 mm (36 mm decrease since 7:00 on August 4)	O.P.+ 2,777 mm (29 mm decrease since 7:00 on August 4)
	Water level of Reactor Building	O.P.+ 3,943 mm (37 mm increase since 7:00 on August 4)	O.P.+ 3,019 mm (129 mm increase since 7:00 on August 4)	O.P.+ 2,732 mm (38 mm decrease since 7:00 on August 4)	O.P.+ 2,866 mm (19 mm decrease since 7:00 on August 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,133 mm (Increase from initial level:5,350 mm, 2 mm increase since 7:00 on August 4) O.P.+ 1,361 mm (Increase from initial level:2,087 mm, 88 mm decrease since 7:00 on August 4) O.P.+ 4,264 mm (Water level from floor:468 mm, 10 mm increase since 7:00 on August 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:16 on July 31   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.