

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 6)**

| | | | | | |
|---|--|---|---|---|---|
| Water Level of the accumulated water (at 7:00 on August 6) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 2,979 mm (66 mm increase since 7:00 on August 5) | O.P.+ 2,596 mm (29 mm decrease since 7:00 on August 5) | — |
| | Water level of Turbine Building | O.P.+ 2,564 mm (10 mm increase since 7:00 on August 5) | O.P.+ 2,983 mm (55 mm increase since 7:00 on August 5) | O.P.+ 2,707 mm (20 mm decrease since 7:00 on August 5) | O.P.+ 2,750 mm (27 mm decrease since 7:00 on August 5) |
| | Water level of Reactor Building | O.P.+ 3,981 mm (38 mm increase since 7:00 on August 5) | O.P.+ 3,071 mm (52 mm increase since 7:00 on August 5) | O.P.+ 2,710 mm (22 mm decrease since 7:00 on August 5) | O.P.+ 2,846 mm (20 mm decrease since 7:00 on August 5) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,137 mm (Increase from initial level:5,354 mm, 4 mm increase since 7:00 on August 5) O.P.+ 1,280 mm (Increase from initial level:2,006 mm, 81 mm decrease since 7:00 on August 5) O.P.+ 4,273 mm (Water level from floor:477 mm, 9 mm increase since 7:00 on August 5) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | — | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:16 on July 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.