

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 7)

Water Level of the accumulated water (at 7:00 on August 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,048 mm (69 mm increase since 7:00 on August 6)	O.P.+ 2,570 mm (26 mm decrease since 7:00 on August 6)	—
	Water level of Turbine Building	O.P.+ 2,574 mm (10 mm increase since 7:00 on August 6)	O.P.+ 3,037 mm (54 mm increase since 7:00 on August 6)	O.P.+ 2,683 mm (24 mm decrease since 7:00 on August 6)	O.P.+ 2,724 mm (26 mm decrease since 7:00 on August 6)
	Water level of Reactor Building	O.P.+ 4,022 mm (41 mm increase since 7:00 on August 6)	O.P.+ 3,122 mm (51 mm increase since 7:00 on August 6)	O.P.+ 2,685 mm (25 mm decrease since 7:00 on August 6)	O.P.+ 2,826 mm (20 mm decrease since 7:00 on August 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,140 mm (Increase from initial level:5,357 mm, 3 mm increase since 7:00 on August 6) O.P.+ 1,206 mm (Increase from initial level:1,932 mm, 74 mm decrease since 7:00 on August 6) O.P.+ 4,281 mm (Water level from floor:485 mm, 8 mm increase since 7:00 on August 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:01 on August 7 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:01 AM on August 7, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.