

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 11)**

Water Level of the accumulated water (at 7:00 on August 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,914 mm (19 mm decrease since 7:00 on August 10)	O.P.+ 2,491 mm (15 mm decrease since 7:00 on August 10)	—
	Water level of Turbine Building	O.P.+ 2,608 mm (13 mm increase since 7:00 on August 10)	O.P.+ 2,924 mm (16 mm decrease since 7:00 on August 10)	O.P.+ 2,632 mm (14 mm decrease since 7:00 on August 10)	O.P.+ 2,646 mm (16 mm decrease since 7:00 on August 10)
	Water level of Reactor Building	O.P.+ 4,181 mm (60 mm increase since 7:00 on August 10)	O.P.+ 3,059 mm (5 mm decrease since 7:00 on August 10)	O.P.+ 2,627 mm (19 mm decrease since 7:00 on August 10)	O.P.+ 2,752 mm (16 mm decrease since 7:00 on August 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,157 mm (Increase from initial level:5,374 mm, 1 mm increase since 7:00 on August 10) O.P.+ 2,320 mm (Increase from initial level:3,046 mm, 232 mm increase since 7:00 on August 10) O.P.+ 4,317 mm (Water level from floor:521 mm, 10 mm increase since 7:00 on August 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on August 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:42 on June 16)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:43 on June 12 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:10 on August 7 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* We initially announced that the destination of transfer from the basement of Unit 2 Turbine Building was the "basement of Unit 3 Turbine Building." We have corrected it to "Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)" on August 12, 2014.				

※ For quick publication of the data of water level, values are provided as reference values.